

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO. 15/2025

DATED: 02.07.2025

It is certified an inspection team headed by **Dr.M.ARULNAMBI, CITY HEALTH OFFICER** from **CORPORATION COUNCIL, PHED** inspected the **SRI LAKSHMI GLOBAL SCHOOL, KANCHIPURAM** on **30.06.2025** and on the basis of Water Test Report bearing no **Lr.no.67232-67232A/JWA/Lan/VLR/2025** dated, **27.06.2025** of **TAMILNADU WATER SUPPLY AND DRAINAGE BOARD, VELLORE** certified that the **SRI LAKSHMI GLOBAL SCHOOL, KANCHIPURAM** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation in the school building & the campus as per norms prescribed by the Central /State/ U.T. Govt.

This certificate is valid till 26.06.2026

M. Arulnambi
CITY HEALTH OFFICER
27/7/2025
Kancheepuram City Municipal Corporation.

Signature with Seal:

TO

SRI LAKSHMI GLOBAL SCHOOL

NO. S-6 TNHB PALLVAN NAGAR

OPPOSITE TO COLLECTOR BUNGALOW

KANCHIPURAM-631502



TEST WATER BEFORE TASTE

twadlabphotos@gmail.com
Ph : 0416 - 2215168

TAMILNADU WATER SUPPLY AND DRAINAGE BOARD
District Level Water Testing Laboratory
Opp. To Muthu Mandapam, Old Katpadi Road, Vellore - 632 004.

TEST REPORT

TO:
SRI LAKSHMI GLOBAL SCHOOL,
No. S6, TNHB Pallavan Nagar,
Near Collector Bangalow,
Kanchipuram.

Sir,

Lr.No.67232-67232A/JWA/Lab/VLR/2025/dt:27.06.2025.

Ref : Lr.No: Dated. 26.06.2025

2.T.O Invoice No: 11429, Dated:26.06.2025. For Rs: 1652/-

The result of analysis for the water samples sent under reference is enclosed.

Scheme: PVT

Source : Bore Well

Location:67232/67232A: School Inside,Sri Lakshmi Global School,Kanchipuram.

BIS 10500:2012	Acceptable Limit	Maximum permissible limit in the absence of alternative source.	Result
I.PHYSICAL EXAMINATIONS			
1. Appearance			67232
2. Colour			Clear
3. Odour	Agreeable	Agreeable	Colourless
4. Turbidity NTU	1	5	0
5. Total dissolved solids mg/L	400	2000	865
6. Electrical conductivity micro mho/cm		-	1235
II.CHEMICAL EXAMINATIONS			
7. pH	6.5-8.5	6.5-8.5	7.35
8. Alkalinity Ph as CaCO ₃ mg/L	-	-	0
9. Alkalinity Total as CaCO ₃ mg/L	200	600	252
10. Total Hardness as CaCO ₃ mg/L	200	600	364
11. Calcium as Ca mg/L	75	200	74
12. Magnesium as mg/L	30	100	43
13. Sodium as Na mg/L	-	-	-
14. Potassium as K mg/L	-	-	-
15. Iron Total as Fe mg/L	0.3	1.0	0.00
16. Manganese as Mn mg/L	0.1	0.3	0.00
17. Free Ammonia as NH ₃ mg/L	0.5	0.5	0.00
18. Nitrite as NO ₂ mg/L	-	-	0.00
19. Nitrate as NO ₃ mg/L	45	45	8
20. Chloride as Cl mg/L	250	1000	178
21. Fluoride as F mg/L	1.0	1.5	0.4
22. Sulphate as SO ₄ mg/L	200	400	92
23. Phosphate as PO ₄ mg/L	-	-	0.00
24. Tidys Test 4Hrs.as O ₂ mg/L	-	-	0.1
III. BACTERIOLOGICAL EXAMINATION (M.F.Technique)			
Fecal Coliform(100ml)	-	-	0

Report:67232: The water sample is chemically Potable.

Report:67232A: The water sample is Bacteriologically Not contaminated.

b. r. y. b. r. y.
 Junior Water Analyst
 TWAD Board
 District Water Testing Laboratory
 Vellore - 632 004